

TRIACTA GATEWAY™/GATEWAY-S™ BACnet

Application Note – (R01)





Contents

Introduction..... 3

Table 1: BACnet tab configuration parameters 4

GATEWAY/GATEWAY-S BACnet Objects..... 4

BACnet Device Object 7

PICS..... 19

Product Description 20

BACnet Standardized Device Profile (Annex L) 21

BACnet Interoperability Building Blocks (BIBBs) Supported 21

Segmentation Capability 26

Standard Object Types Supported 26

Properties that are Writable and Optional are indicated..... 26

Character Sets Supported 28

Network Security Options..... 28



Introduction

This guide describes the BACnet IP interface for the GATEWAY™/GATEWAY-S™ meters. This interface has been designed to comply with the Standard ANSI/ASHRAE Standard 135-2016 (*Protocol Revision 16.1*). It can be used with any BTL- compliant BACnet IP application to read meter measurement data as part of an integrated building energy management system.

This interface is fully BTL-tested and BTL-compliant. Refer to “Appendix A: Product Implementation Conformance Statement” on page 9 for the details the GATEWAY™/GATEWAY-S™ meters.

This guide provides information about configuring the BACnet interface, and describes the BACnet objects and services supported by the GATEWAY™/GATEWAY-S™ meters and the specific meter data that can be read from each meter, as follows:

- “GATEWAY™/GATEWAY-S™ meter BACnet configuration” on page 5
- “GATEWAY™/GATEWAY-S™ meter BACnet objects” on page 4
- “BACnet device object” on page 4
- “Analog input objects” on page 5
- “Accumulator objects” on page 6
- “Appendix A: Product Implementation Conformance Statement” (PICS) on page 19

GATEWAY™/GATEWAY-S™ meter BACnet configuration

The BACnet IP interface for the GATEWAY™/GATEWAY-S™ series meters is configured using the TRIACTA Configuration Tool; refer to the GATEWAY™/GATEWAY-S™ Configuration Guide 930-149-01-A.01 for information and instructions on using the tool to configure the meters.

Figure 1 shows the BACnet configuration tab in the Configuration Tool and Table 1 provides a programming description of each field.

Figure 1: BACnet tab in the Report section

Protocols Configuration

Modbus & RTU BACnet

Enabled:

Configuration

Device ID: 4194303 Retries: 3

Network port: 47808 Timeout: 5000

BBMD timeout: 60000 DST Status

BBMD address: UTC Offset: 0

Description: GATEWAY Location: Carleton Place

Vendor ID: 425 Object name: Triacta Gateway

Vendor name: Triacta

**Table 1: BACnet tab configuration parameters**

| Parameter Description | Description | Programmable |
|-----------------------|--|--------------|
| Device ID | User specified BACnet ID number of the meter (between 0 and 4194303). This ID should be different for every device on the BACnet network. Default is 4194303 | ✓ |
| Network port | DEVICE ID: <i>(UDP Port number for BACnet/IP communications. Default is 47808)</i> | ✓ |
| BBMD Timeout | The amount of time (seconds) allowed for connection to a BBMD device (if required). Default is 60000 seconds | ✓ |
| BBMD Address | The IP address of the BBMD device that controls all devices in the BACnet network (if required). The GATEWAY™/GATEWAY-S™ meters will register with the BBMD as a foreign device. Default is blank (No BBMD devices in the network) | ✓ |
| Description | A user definable description of the BACnet device. Default is GATEWAY | ✓ |
| Vendor ID | BACnet Vendor Identification number. Default is 425 | ✓ |
| Vendor Name | METERGY, TRIACTA Div. | ✓ |
| Software Version | The software version of the BACnet component (fixed) | ✓ |
| UTC Offset | Fixed at 0. All time information is reported in UTC | ✓ |
| Location | A user definable description of the physical location of the BACnet device Default is Unknown | ✓ |
| Object Name | GATEWAY (Fixed) | ✓ |

GATEWAY/GATEWAY-S BACnet Objects

Once the GATEWAY™/GATEWAY-S™ meter BACnet/IP interface is properly configured, the following BACnet objects will be accessible from any BTL-compliant BACnet/IP application and will be discovered by most BACnet Discovery tools and support the following object types.

- Device object
- Analog input objects
- Accumulator objects

These objects provide device-specific information as described in the following sections.



Model name

Please see the details of supported measurement module types, model name and numbering strategy in Appendix 2.

Segmentation

BACnet packet segmentation is NOT supported by the GATEWAY™/GATEWAY-S™ series meters. TRIACTA recommends using the ReadProperty service to read single objects. If you use the ReadPropertyMultiple service, you must limit the list of objects to be read and do not use reading-all with this service.

Analog input objects

The following analog input objects identify the GATEWAY™/GATEWAY-S™ meter data that is returned in the present value property when reading the specified analog input object.

Except where indicated, all analog input objects are updated every 5 seconds.

Per meter circuit (Meter x)

The following analog input objects are reported for each meter circuit (Meter x).

Per meter circuit (Meter x)

The following analog input objects are reported for each meter circuit (Meter x).

| Object name | Description | Units |
|------------------------|--|-----------------------------|
| Meter x Active Power | Current active (real) power | Watts |
| Meter x Reactive Power | Current reactive power | VARs - Volt Ampere Reactive |
| Meter x Apparent Power | Current apparent power | VAs -Volt Ampere |
| Meter x Power Factor | Current power factor | pf |
| Meter x Peak Demand | Highest demand measured over any demand time interval since either the meter was commissioned or since the last Peak Demand Reset. | Watts |
| Meter x Present Demand | Demand measured for the most recent demand time interval. | Watts |

The number of discovered meter circuits is determined by the model number and configuration of the GATEWAY™/GATEWAY-S™ meter.

NOTE: Peak/ Present Demand must be enabled in the **Types** tab of the **Report** section in the GATEWAY™/GATEWAY-S™ configuration tool to enable demand data. The demand calculation type (Block or Sliding Window Demand) and the demand interval duration are specified during meter configuration. Refer to the GATEWAY™/GATEWAY-S™ Configuration Guide for details on how to configure the parameters in the Report section of the configuration tool.

Per meter circuit and meter element (Meter x, Element p)

The following analog input objects are reported for each meter element (p) on each meter circuit (x).



| Object name | Description | Units |
|----------------------------------|--|-----------------------|
| Meter x Element p Current | Instantaneous current per element | Amperes |
| Meter x Element p Voltage | Instantaneous voltage per element | Volts |
| Meter x Element p Power Factor | Instantaneous power factor per element | pf |
| Meter x Element p Phase Angle | Instantaneous phase angle per element | Degrees-phase |
| Meter x Element p Active Power | Instantaneous active power per element | Watts |
| Meter x Element p Reactive Power | Instantaneous reactive power per element | Volt Amperes Reactive |
| Meter x Element p Apparent Power | Instantaneous apparent power per element | Volt Amperes |

Refer to Appendix 2 for the number of circuits and elements for each GATEWAY™/GATEWAY-S™ model number and configuration.

A mixed configuration is given to show the details of how the objects are displayed in accordance with it in the **BACnet Device Object** which also includes pulses.

NOTE: The **Pulses** report type must be enabled in the **Types** tab of the **Report** section in the GATEWAY™/GATEWAY-S™ configuration tool to enable the pulse count registers. Refer to the GATEWAY™/GATEWAY-S™ Meters Configuration Guide for details on how to enable the pulse count and set the pulse scale factor parameters in the configuration tool.

Accumulator objects

The following accumulator objects identify the GATEWAY™/GATEWAY-S™ meter data that is returned in the present value property when reading the specified accumulator object. These objects report the total measured units from when the meter was commissioned or from when the register last overflowed, to present.

| Object Name | Description | Units |
|--|--|----------------------------|
| Meter x Active Energy Delivered Register | Cumulative total of active (real) energy delivered | Watt-hours |
| Meter x Active Energy Received Register | Cumulative total of active (real) energy received | Watt-hours |
| Meter x Reactive Energy Delivered Register | Cumulative total of reactive (real) energy delivered | volt-ampere-reactive-hours |
| Meter x Reactive Energy Received Register | Cumulative total of reactive (real) energy received | volt-ampere-reactive-hours |
| Meter x Apparent Energy Register | Cumulative total of apparent energy delivered | |
| Pulse 1-48 Input register | Cumulative total pulse count, multiplied by the pulse scale factor | |



BACnet Device Object

The BACnet object details are provided as a function of the meter configuration in this section. There are module options which have different circuit configuration capabilities and affect the number of appearances of analog objects. The BACnet object response is dynamic in that it will only represent the configured meter points and their elements. It will not show blank objects where no meter points or external Pulse inputs are configured.

The Maximum objects possible are;

- Measurement Module objects single element all units of measure enabled = 768
- External Pulse module objects fully loaded (48 Pairs) = 48

Mixed Configuration Full Example

This is a demonstration of the relationship between the meter configuration and how the BACnet objects appear in accordance with it. Please refer to the GATEWAY Configuration Guide 930-149-01-A.01 for more details of meter configuration using the GATEWAY Configuration Tool. All “Record Types were enabled for this demonstration which will produce multiple outputs per meter point. What follows are the web pages of a meter configuration and the associated BACnet output.

Web Page Output

| Module 1 | | Module 2 | | Module 3 | | Module 4 | |
|-------------------|-------------|-------------------|-------------|-------------------|-------------|-------------------|------------|
| Type | Energy 80mA | Type | Energy 80mA | Type | Energy 80mA | Type | Pulse |
| Status | OK | Status | OK | Status | OK | Status | OK |
| Part Number | 500-074-02 | Part Number | 500-074-02 | Part Number | 500-044-02 | Part Number | 500-043-01 |
| Hardware Revision | B.01 | Hardware Revision | B.01 | Hardware Revision | B.00 | Hardware Revision | B.00 |
| Serial Number | 219202007 | Serial Number | 219202008 | Serial Number | 218350403 | Serial Number | 117400217 |
| Firmware Revision | NONE | Firmware Revision | NONE | Firmware Revision | NONE | Firmware Revision | 1.01 |
| Firmware Build | NONE | Firmware Build | NONE | Firmware Build | NONE | Firmware Build | 1004 |
| Date | OCT-18-2019 | Date | OCT-18-2019 | Date | 15-Feb-22 | Date | 14-Nov-17 |
| Integrator 1 | 0 | Integrator 1 | 0 | Integrator 1 | 0 | Integrator 1 | 0 |
| Integrator 2 | 0 | Integrator 2 | 0 | Integrator 2 | 0 | Integrator 2 | 0 |
| Integrator 3 | 0 | Integrator 3 | 0 | Integrator 3 | 0 | Integrator 3 | 0 |
| Integrator 4 | 0 | Integrator 4 | 0 | Integrator 4 | 0 | Integrator 4 | 0 |

| Meter ID | Badge # | Ref. | Slot | Circuit | Phase | Meter ID | Badge # | Ref. | Slot | Circuit | Phase |
|-----------|------------|-------|------|---------|-------|-----------|------------|-------|------|---------|-------|
| Meter 01 | Unassigned | | | | | Meter 09 | Unassigned | | | | |
| Element 1 | | VREF1 | 1 | 1 | A | Element 1 | | VREF1 | 2 | 5 | B |
| Element 2 | | VREF1 | 1 | 2 | B | Element 2 | | VREF1 | 2 | 6 | C |
| Meter 02 | Unassigned | | | | | Meter 10 | Unassigned | | | | |
| Element 1 | | VREF1 | 1 | 3 | C | Element 1 | | VREF1 | 2 | 7 | A |
| Element 2 | | VREF1 | 1 | 4 | A | Element 2 | | VREF1 | 2 | 8 | B |
| Meter 03 | Unassigned | | | | | Meter 11 | Unassigned | | | | |
| Element 1 | | VREF1 | 1 | 5 | B | Element 1 | | VREF1 | 2 | 9 | C |
| Element 2 | | VREF1 | 1 | 6 | C | Element 2 | | VREF1 | 2 | 10 | A |
| Meter 04 | Unassigned | | | | | Meter 12 | Unassigned | | | | |
| Element 1 | | VREF1 | 1 | 7 | A | Element 1 | | VREF1 | 2 | 11 | B |
| Element 2 | | VREF1 | 1 | 8 | B | Element 2 | | VREF1 | 2 | 12 | C |
| Meter 05 | Unassigned | | | | | Meter 13 | Unassigned | | | | |
| Element 1 | | VREF1 | 1 | 9 | C | Element 1 | | VREF1 | 3 | 1 | A |
| Element 2 | | VREF1 | 1 | 10 | A | Element 2 | | VREF1 | 3 | 2 | B |
| Meter 06 | Unassigned | | | | | Element 3 | | VREF1 | 3 | 3 | C |
| Element 1 | | VREF1 | 1 | 11 | B | Meter 14 | Unassigned | | | | |
| Element 2 | | VREF1 | 1 | 12 | C | Element 1 | | VREF1 | 3 | 4 | A |
| Meter 07 | Unassigned | | | | | Element 2 | | VREF1 | 3 | 5 | B |
| Element 1 | | VREF1 | 2 | 1 | A | Element 3 | | VREF1 | 3 | 6 | C |
| Element 2 | | VREF1 | 2 | 2 | B | Meter 15 | Unassigned | | | | |
| Meter 08 | Unassigned | | | | | Element 1 | | VREF1 | 3 | 7 | A |
| Element 1 | | VREF1 | 2 | 3 | C | Element 2 | | VREF1 | 3 | 8 | B |
| Element 2 | | VREF1 | 2 | 4 | A | Element 3 | | VREF1 | 3 | 9 | C |

| Enabled Interval Reports |
|--------------------------|
| Wh Delivered |
| Wh Received |
| VARh Delivered |
| VARh Received |
| VAh |
| Pulse |
| Present Demand |
| Present VA Demand |
| Voltage |
| Peak Current |

| Enabled Register Reports |
|--------------------------|
| Wh Delivered |
| Wh Received |
| VARh Delivered |
| VARh Received |
| VAh |
| Pulse |
| Peak Demand |
| Peak VA Demand |

BACnet Mixed Configuration Output



| Object Type | Object Id | Object Name | Value | Description |
|-------------|-----------|----------------------------------|-------|----------------------------------|
| Device | 123456 | " " | | Triacrt |
| AnalogInput | 0 | Meter 1 Active Power | 0 | Meter 1 Active Power |
| AnalogInput | 1 | Meter 1 Reactive Power | 0 | Meter 1 Reactive Power |
| AnalogInput | 2 | Meter 1 Apparent Power | 0 | Meter 1 Apparent Power |
| AnalogInput | 3 | Meter 1 Power Factor | 0 | Meter 1 Power Factor |
| AnalogInput | 4 | Meter 1 Demand W | 0 | Meter 1 Demand W |
| AnalogInput | 5 | Meter 1 Demand W Present | 0 | Meter 1 Demand W Present |
| AnalogInput | 6 | Meter 1 Demand VA | 0 | Meter 1 Demand VA |
| AnalogInput | 7 | Meter 1 Demand VA Present | 0 | Meter 1 Demand VA Present |
| AnalogInput | 8 | Meter 1 Element 1 Power | 0 | Meter 1 Element 1 Power |
| AnalogInput | 9 | Meter 1 Element 1 Reactive Power | 0 | Meter 1 Element 1 Reactive Power |
| AnalogInput | 10 | Meter 1 Element 1 Apparent Power | 0 | Meter 1 Element 1 Apparent Power |
| AnalogInput | 11 | Meter 1 Element 1 Power Factor | 0 | Meter 1 Element 1 Power Factor |
| AnalogInput | 12 | Meter 1 Element 1 Angle | 0 | Meter 1 Element 1 Angle |
| AnalogInput | 13 | Meter 1 Element 1 Current | 0 | Meter 1 Element 1 Current |
| AnalogInput | 14 | Meter 1 Element 1 Voltage | 0 | Meter 1 Element 1 Voltage |
| AnalogInput | 15 | Meter 1 Element 2 Power | 0 | Meter 1 Element 2 Power |
| AnalogInput | 16 | Meter 1 Element 2 Reactive Power | 0 | Meter 1 Element 2 Reactive Power |
| AnalogInput | 17 | Meter 1 Element 2 Apparent Power | 0 | Meter 1 Element 2 Apparent Power |
| AnalogInput | 18 | Meter 1 Element 2 Power Factor | 0 | Meter 1 Element 2 Power Factor |
| AnalogInput | 19 | Meter 1 Element 2 Angle | 0 | Meter 1 Element 2 Angle |
| AnalogInput | 20 | Meter 1 Element 2 Current | 0 | Meter 1 Element 2 Current |
| AnalogInput | 21 | Meter 1 Element 2 Voltage | 0 | Meter 1 Element 2 Voltage |
| AnalogInput | 22 | Meter 2 Active Power | 0 | Meter 2 Active Power |
| AnalogInput | 23 | Meter 2 Reactive Power | 0 | Meter 2 Reactive Power |
| AnalogInput | 24 | Meter 2 Apparent Power | 0 | Meter 2 Apparent Power |
| AnalogInput | 25 | Meter 2 Power Factor | 0 | Meter 2 Power Factor |
| AnalogInput | 26 | Meter 2 Demand W | 0 | Meter 2 Demand W |
| AnalogInput | 27 | Meter 2 Demand W Present | 0 | Meter 2 Demand W Present |
| AnalogInput | 28 | Meter 2 Demand VA | 0 | Meter 2 Demand VA |
| AnalogInput | 29 | Meter 2 Demand VA Present | 0 | Meter 2 Demand VA Present |
| AnalogInput | 30 | Meter 2 Element 1 Power | 0 | Meter 2 Element 1 Power |
| AnalogInput | 31 | Meter 2 Element 1 Reactive Power | 0 | Meter 2 Element 1 Reactive Power |
| AnalogInput | 32 | Meter 2 Element 1 Apparent Power | 0 | Meter 2 Element 1 Apparent Power |
| AnalogInput | 33 | Meter 2 Element 1 Power Factor | 0 | Meter 2 Element 1 Power Factor |
| AnalogInput | 34 | Meter 2 Element 1 Angle | 0 | Meter 2 Element 1 Angle |
| AnalogInput | 35 | Meter 2 Element 1 Current | 0 | Meter 2 Element 1 Current |
| AnalogInput | 36 | Meter 2 Element 1 Voltage | 0 | Meter 2 Element 1 Voltage |
| AnalogInput | 37 | Meter 2 Element 2 Power | 0 | Meter 2 Element 2 Power |
| AnalogInput | 38 | Meter 2 Element 2 Reactive Power | 0 | Meter 2 Element 2 Reactive Power |
| AnalogInput | 39 | Meter 2 Element 2 Apparent Power | 0 | Meter 2 Element 2 Apparent Power |
| AnalogInput | 40 | Meter 2 Element 2 Power Factor | 0 | Meter 2 Element 2 Power Factor |
| AnalogInput | 41 | Meter 2 Element 2 Angle | 0 | Meter 2 Element 2 Angle |
| AnalogInput | 42 | Meter 2 Element 2 Current | 0 | Meter 2 Element 2 Current |
| AnalogInput | 43 | Meter 2 Element 2 Voltage | 0 | Meter 2 Element 2 Voltage |
| AnalogInput | 44 | Meter 3 Active Power | 0 | Meter 3 Active Power |
| AnalogInput | 45 | Meter 3 Reactive Power | 0 | Meter 3 Reactive Power |
| AnalogInput | 46 | Meter 3 Apparent Power | 0 | Meter 3 Apparent Power |
| AnalogInput | 47 | Meter 3 Power Factor | 0 | Meter 3 Power Factor |
| AnalogInput | 48 | Meter 3 Demand W | 0 | Meter 3 Demand W |
| AnalogInput | 49 | Meter 3 Demand W Present | 0 | Meter 3 Demand W Present |
| AnalogInput | 50 | Meter 3 Demand VA | 0 | Meter 3 Demand VA |
| AnalogInput | 51 | Meter 3 Demand VA Present | 0 | Meter 3 Demand VA Present |
| AnalogInput | 52 | Meter 3 Element 1 Power | 0 | Meter 3 Element 1 Power |
| AnalogInput | 53 | Meter 3 Element 1 Reactive Power | 0 | Meter 3 Element 1 Reactive Power |
| AnalogInput | 54 | Meter 3 Element 1 Apparent Power | 0 | Meter 3 Element 1 Apparent Power |



| | | | | |
|-------------|-----|----------------------------------|---|----------------------------------|
| AnalogInput | 55 | Meter 3 Element 1 Power Factor | 0 | Meter 3 Element 1 Power Factor |
| AnalogInput | 56 | Meter 3 Element 1 Angle | 0 | Meter 3 Element 1 Angle |
| AnalogInput | 57 | Meter 3 Element 1 Current | 0 | Meter 3 Element 1 Current |
| AnalogInput | 58 | Meter 3 Element 1 Voltage | 0 | Meter 3 Element 1 Voltage |
| AnalogInput | 59 | Meter 3 Element 2 Power | 0 | Meter 3 Element 2 Power |
| AnalogInput | 60 | Meter 3 Element 2 Reactive Power | 0 | Meter 3 Element 2 Reactive Power |
| AnalogInput | 61 | Meter 3 Element 2 Apparent Power | 0 | Meter 3 Element 2 Apparent Power |
| AnalogInput | 62 | Meter 3 Element 2 Power Factor | 0 | Meter 3 Element 2 Power Factor |
| AnalogInput | 63 | Meter 3 Element 2 Angle | 0 | Meter 3 Element 2 Angle |
| AnalogInput | 64 | Meter 3 Element 2 Current | 0 | Meter 3 Element 2 Current |
| AnalogInput | 65 | Meter 3 Element 2 Voltage | 0 | Meter 3 Element 2 Voltage |
| AnalogInput | 66 | Meter 4 Active Power | 0 | Meter 4 Active Power |
| AnalogInput | 67 | Meter 4 Reactive Power | 0 | Meter 4 Reactive Power |
| AnalogInput | 68 | Meter 4 Apparent Power | 0 | Meter 4 Apparent Power |
| AnalogInput | 69 | Meter 4 Power Factor | 0 | Meter 4 Power Factor |
| AnalogInput | 70 | Meter 4 Demand W | 0 | Meter 4 Demand W |
| AnalogInput | 71 | Meter 4 Demand W Present | 0 | Meter 4 Demand W Present |
| AnalogInput | 72 | Meter 4 Demand VA | 0 | Meter 4 Demand VA |
| AnalogInput | 73 | Meter 4 Demand VA Present | 0 | Meter 4 Demand VA Present |
| AnalogInput | 74 | Meter 4 Element 1 Power | 0 | Meter 4 Element 1 Power |
| AnalogInput | 75 | Meter 4 Element 1 Reactive Power | 0 | Meter 4 Element 1 Reactive Power |
| AnalogInput | 76 | Meter 4 Element 1 Apparent Power | 0 | Meter 4 Element 1 Apparent Power |
| AnalogInput | 77 | Meter 4 Element 1 Power Factor | 0 | Meter 4 Element 1 Power Factor |
| AnalogInput | 78 | Meter 4 Element 1 Angle | 0 | Meter 4 Element 1 Angle |
| AnalogInput | 79 | Meter 4 Element 1 Current | 0 | Meter 4 Element 1 Current |
| AnalogInput | 80 | Meter 4 Element 1 Voltage | 0 | Meter 4 Element 1 Voltage |
| AnalogInput | 81 | Meter 4 Element 2 Power | 0 | Meter 4 Element 2 Power |
| AnalogInput | 82 | Meter 4 Element 2 Reactive Power | 0 | Meter 4 Element 2 Reactive Power |
| AnalogInput | 83 | Meter 4 Element 2 Apparent Power | 0 | Meter 4 Element 2 Apparent Power |
| AnalogInput | 84 | Meter 4 Element 2 Power Factor | 0 | Meter 4 Element 2 Power Factor |
| AnalogInput | 85 | Meter 4 Element 2 Angle | 0 | Meter 4 Element 2 Angle |
| AnalogInput | 86 | Meter 4 Element 2 Current | 0 | Meter 4 Element 2 Current |
| AnalogInput | 87 | Meter 4 Element 2 Voltage | 0 | Meter 4 Element 2 Voltage |
| AnalogInput | 88 | Meter 5 Active Power | 0 | Meter 5 Active Power |
| AnalogInput | 89 | Meter 5 Reactive Power | 0 | Meter 5 Reactive Power |
| AnalogInput | 90 | Meter 5 Apparent Power | 0 | Meter 5 Apparent Power |
| AnalogInput | 91 | Meter 5 Power Factor | 0 | Meter 5 Power Factor |
| AnalogInput | 92 | Meter 5 Demand W | 0 | Meter 5 Demand W |
| AnalogInput | 93 | Meter 5 Demand W Present | 0 | Meter 5 Demand W Present |
| AnalogInput | 94 | Meter 5 Demand VA | 0 | Meter 5 Demand VA |
| AnalogInput | 95 | Meter 5 Demand VA Present | 0 | Meter 5 Demand VA Present |
| AnalogInput | 96 | Meter 5 Element 1 Power | 0 | Meter 5 Element 1 Power |
| AnalogInput | 97 | Meter 5 Element 1 Reactive Power | 0 | Meter 5 Element 1 Reactive Power |
| AnalogInput | 98 | Meter 5 Element 1 Apparent Power | 0 | Meter 5 Element 1 Apparent Power |
| AnalogInput | 99 | Meter 5 Element 1 Power Factor | 0 | Meter 5 Element 1 Power Factor |
| AnalogInput | 100 | Meter 5 Element 1 Angle | 0 | Meter 5 Element 1 Angle |
| AnalogInput | 101 | Meter 5 Element 1 Current | 0 | Meter 5 Element 1 Current |
| AnalogInput | 102 | Meter 5 Element 1 Voltage | 0 | Meter 5 Element 1 Voltage |
| AnalogInput | 103 | Meter 5 Element 2 Power | 0 | Meter 5 Element 2 Power |
| AnalogInput | 104 | Meter 5 Element 2 Reactive Power | 0 | Meter 5 Element 2 Reactive Power |
| AnalogInput | 105 | Meter 5 Element 2 Apparent Power | 0 | Meter 5 Element 2 Apparent Power |
| AnalogInput | 106 | Meter 5 Element 2 Power Factor | 0 | Meter 5 Element 2 Power Factor |
| AnalogInput | 107 | Meter 5 Element 2 Angle | 0 | Meter 5 Element 2 Angle |
| AnalogInput | 108 | Meter 5 Element 2 Current | 0 | Meter 5 Element 2 Current |
| AnalogInput | 109 | Meter 5 Element 2 Voltage | 0 | Meter 5 Element 2 Voltage |
| AnalogInput | 110 | Meter 6 Active Power | 0 | Meter 6 Active Power |



| | | | | |
|-------------|-----|----------------------------------|---|----------------------------------|
| AnalogInput | 111 | Meter 6 Reactive Power | 0 | Meter 6 Reactive Power |
| AnalogInput | 112 | Meter 6 Apparent Power | 0 | Meter 6 Apparent Power |
| AnalogInput | 113 | Meter 6 Power Factor | 0 | Meter 6 Power Factor |
| AnalogInput | 114 | Meter 6 Demand W | 0 | Meter 6 Demand W |
| AnalogInput | 115 | Meter 6 Demand W Present | 0 | Meter 6 Demand W Present |
| AnalogInput | 116 | Meter 6 Demand VA | 0 | Meter 6 Demand VA |
| AnalogInput | 117 | Meter 6 Demand VA Present | 0 | Meter 6 Demand VA Present |
| AnalogInput | 118 | Meter 6 Element 1 Power | 0 | Meter 6 Element 1 Power |
| AnalogInput | 119 | Meter 6 Element 1 Reactive Power | 0 | Meter 6 Element 1 Reactive Power |
| AnalogInput | 120 | Meter 6 Element 1 Apparent Power | 0 | Meter 6 Element 1 Apparent Power |
| AnalogInput | 121 | Meter 6 Element 1 Power Factor | 0 | Meter 6 Element 1 Power Factor |
| AnalogInput | 122 | Meter 6 Element 1 Angle | 0 | Meter 6 Element 1 Angle |
| AnalogInput | 123 | Meter 6 Element 1 Current | 0 | Meter 6 Element 1 Current |
| AnalogInput | 124 | Meter 6 Element 1 Voltage | 0 | Meter 6 Element 1 Voltage |
| AnalogInput | 125 | Meter 6 Element 2 Power | 0 | Meter 6 Element 2 Power |
| AnalogInput | 126 | Meter 6 Element 2 Reactive Power | 0 | Meter 6 Element 2 Reactive Power |
| AnalogInput | 127 | Meter 6 Element 2 Apparent Power | 0 | Meter 6 Element 2 Apparent Power |
| AnalogInput | 128 | Meter 6 Element 2 Power Factor | 0 | Meter 6 Element 2 Power Factor |
| AnalogInput | 129 | Meter 6 Element 2 Angle | 0 | Meter 6 Element 2 Angle |
| AnalogInput | 130 | Meter 6 Element 2 Current | 0 | Meter 6 Element 2 Current |
| AnalogInput | 131 | Meter 6 Element 2 Voltage | 0 | Meter 6 Element 2 Voltage |
| AnalogInput | 132 | Meter 7 Active Power | 0 | Meter 7 Active Power |
| AnalogInput | 133 | Meter 7 Reactive Power | 0 | Meter 7 Reactive Power |
| AnalogInput | 134 | Meter 7 Apparent Power | 0 | Meter 7 Apparent Power |
| AnalogInput | 135 | Meter 7 Power Factor | 0 | Meter 7 Power Factor |
| AnalogInput | 136 | Meter 7 Demand W | 0 | Meter 7 Demand W |
| AnalogInput | 137 | Meter 7 Demand W Present | 0 | Meter 7 Demand W Present |
| AnalogInput | 138 | Meter 7 Demand VA | 0 | Meter 7 Demand VA |
| AnalogInput | 139 | Meter 7 Demand VA Present | 0 | Meter 7 Demand VA Present |
| AnalogInput | 140 | Meter 7 Element 1 Power | 0 | Meter 7 Element 1 Power |
| AnalogInput | 141 | Meter 7 Element 1 Reactive Power | 0 | Meter 7 Element 1 Reactive Power |
| AnalogInput | 142 | Meter 7 Element 1 Apparent Power | 0 | Meter 7 Element 1 Apparent Power |
| AnalogInput | 143 | Meter 7 Element 1 Power Factor | 0 | Meter 7 Element 1 Power Factor |
| AnalogInput | 144 | Meter 7 Element 1 Angle | 0 | Meter 7 Element 1 Angle |
| AnalogInput | 145 | Meter 7 Element 1 Current | 0 | Meter 7 Element 1 Current |
| AnalogInput | 146 | Meter 7 Element 1 Voltage | 0 | Meter 7 Element 1 Voltage |
| AnalogInput | 147 | Meter 7 Element 2 Power | 0 | Meter 7 Element 2 Power |
| AnalogInput | 148 | Meter 7 Element 2 Reactive Power | 0 | Meter 7 Element 2 Reactive Power |
| AnalogInput | 149 | Meter 7 Element 2 Apparent Power | 0 | Meter 7 Element 2 Apparent Power |
| AnalogInput | 150 | Meter 7 Element 2 Power Factor | 0 | Meter 7 Element 2 Power Factor |
| AnalogInput | 151 | Meter 7 Element 2 Angle | 0 | Meter 7 Element 2 Angle |
| AnalogInput | 152 | Meter 7 Element 2 Current | 0 | Meter 7 Element 2 Current |
| AnalogInput | 153 | Meter 7 Element 2 Voltage | 0 | Meter 7 Element 2 Voltage |
| AnalogInput | 154 | Meter 8 Active Power | 0 | Meter 8 Active Power |
| AnalogInput | 155 | Meter 8 Reactive Power | 0 | Meter 8 Reactive Power |
| AnalogInput | 156 | Meter 8 Apparent Power | 0 | Meter 8 Apparent Power |
| AnalogInput | 157 | Meter 8 Power Factor | 0 | Meter 8 Power Factor |
| AnalogInput | 158 | Meter 8 Demand W | 0 | Meter 8 Demand W |
| AnalogInput | 159 | Meter 8 Demand W Present | 0 | Meter 8 Demand W Present |
| AnalogInput | 160 | Meter 8 Demand VA | 0 | Meter 8 Demand VA |
| AnalogInput | 161 | Meter 8 Demand VA Present | 0 | Meter 8 Demand VA Present |
| AnalogInput | 162 | Meter 8 Element 1 Power | 0 | Meter 8 Element 1 Power |
| AnalogInput | 163 | Meter 8 Element 1 Reactive Power | 0 | Meter 8 Element 1 Reactive Power |
| AnalogInput | 164 | Meter 8 Element 1 Apparent Power | 0 | Meter 8 Element 1 Apparent Power |
| AnalogInput | 165 | Meter 8 Element 1 Power Factor | 0 | Meter 8 Element 1 Power Factor |
| AnalogInput | 166 | Meter 8 Element 1 Angle | 0 | Meter 8 Element 1 Angle |
| AnalogInput | 167 | Meter 8 Element 1 Current | 0 | Meter 8 Element 1 Current |



| | | | | |
|-------------|-----|-----------------------------------|---|-----------------------------------|
| AnalogInput | 168 | Meter 8 Element 1 Voltage | 0 | Meter 8 Element 1 Voltage |
| AnalogInput | 169 | Meter 8 Element 2 Power | 0 | Meter 8 Element 2 Power |
| AnalogInput | 170 | Meter 8 Element 2 Reactive Power | 0 | Meter 8 Element 2 Reactive Power |
| AnalogInput | 171 | Meter 8 Element 2 Apparent Power | 0 | Meter 8 Element 2 Apparent Power |
| AnalogInput | 172 | Meter 8 Element 2 Power Factor | 0 | Meter 8 Element 2 Power Factor |
| AnalogInput | 173 | Meter 8 Element 2 Angle | 0 | Meter 8 Element 2 Angle |
| AnalogInput | 174 | Meter 8 Element 2 Current | 0 | Meter 8 Element 2 Current |
| AnalogInput | 175 | Meter 8 Element 2 Voltage | 0 | Meter 8 Element 2 Voltage |
| AnalogInput | 176 | Meter 9 Active Power | 0 | Meter 9 Active Power |
| AnalogInput | 177 | Meter 9 Reactive Power | 0 | Meter 9 Reactive Power |
| AnalogInput | 178 | Meter 9 Apparent Power | 0 | Meter 9 Apparent Power |
| AnalogInput | 179 | Meter 9 Power Factor | 0 | Meter 9 Power Factor |
| AnalogInput | 180 | Meter 9 Demand W | 0 | Meter 9 Demand W |
| AnalogInput | 181 | Meter 9 Demand W Present | 0 | Meter 9 Demand W Present |
| AnalogInput | 182 | Meter 9 Demand VA | 0 | Meter 9 Demand VA |
| AnalogInput | 183 | Meter 9 Demand VA Present | 0 | Meter 9 Demand VA Present |
| AnalogInput | 184 | Meter 9 Element 1 Power | 0 | Meter 9 Element 1 Power |
| AnalogInput | 185 | Meter 9 Element 1 Reactive Power | 0 | Meter 9 Element 1 Reactive Power |
| AnalogInput | 186 | Meter 9 Element 1 Apparent Power | 0 | Meter 9 Element 1 Apparent Power |
| AnalogInput | 187 | Meter 9 Element 1 Power Factor | 0 | Meter 9 Element 1 Power Factor |
| AnalogInput | 188 | Meter 9 Element 1 Angle | 0 | Meter 9 Element 1 Angle |
| AnalogInput | 189 | Meter 9 Element 1 Current | 0 | Meter 9 Element 1 Current |
| AnalogInput | 190 | Meter 9 Element 1 Voltage | 0 | Meter 9 Element 1 Voltage |
| AnalogInput | 191 | Meter 9 Element 2 Power | 0 | Meter 9 Element 2 Power |
| AnalogInput | 192 | Meter 9 Element 2 Reactive Power | 0 | Meter 9 Element 2 Reactive Power |
| AnalogInput | 193 | Meter 9 Element 2 Apparent Power | 0 | Meter 9 Element 2 Apparent Power |
| AnalogInput | 194 | Meter 9 Element 2 Power Factor | 0 | Meter 9 Element 2 Power Factor |
| AnalogInput | 195 | Meter 9 Element 2 Angle | 0 | Meter 9 Element 2 Angle |
| AnalogInput | 196 | Meter 9 Element 2 Current | 0 | Meter 9 Element 2 Current |
| AnalogInput | 197 | Meter 9 Element 2 Voltage | 0 | Meter 9 Element 2 Voltage |
| AnalogInput | 198 | Meter 10 Active Power | 0 | Meter 10 Active Power |
| AnalogInput | 199 | Meter 10 Reactive Power | 0 | Meter 10 Reactive Power |
| AnalogInput | 200 | Meter 10 Apparent Power | 0 | Meter 10 Apparent Power |
| AnalogInput | 201 | Meter 10 Power Factor | 0 | Meter 10 Power Factor |
| AnalogInput | 202 | Meter 10 Demand W | 0 | Meter 10 Demand W |
| AnalogInput | 203 | Meter 10 Demand W Present | 0 | Meter 10 Demand W Present |
| AnalogInput | 204 | Meter 10 Demand VA | 0 | Meter 10 Demand VA |
| AnalogInput | 205 | Meter 10 Demand VA Present | 0 | Meter 10 Demand VA Present |
| AnalogInput | 206 | Meter 10 Element 1 Power | 0 | Meter 10 Element 1 Power |
| AnalogInput | 207 | Meter 10 Element 1 Reactive Power | 0 | Meter 10 Element 1 Reactive Power |
| AnalogInput | 208 | Meter 10 Element 1 Apparent Power | 0 | Meter 10 Element 1 Apparent Power |
| AnalogInput | 209 | Meter 10 Element 1 Power Factor | 0 | Meter 10 Element 1 Power Factor |
| AnalogInput | 210 | Meter 10 Element 1 Angle | 0 | Meter 10 Element 1 Angle |
| AnalogInput | 211 | Meter 10 Element 1 Current | 0 | Meter 10 Element 1 Current |
| AnalogInput | 212 | Meter 10 Element 1 Voltage | 0 | Meter 10 Element 1 Voltage |
| AnalogInput | 213 | Meter 10 Element 2 Power | 0 | Meter 10 Element 2 Power |
| AnalogInput | 214 | Meter 10 Element 2 Reactive Power | 0 | Meter 10 Element 2 Reactive Power |
| AnalogInput | 215 | Meter 10 Element 2 Apparent Power | 0 | Meter 10 Element 2 Apparent Power |
| AnalogInput | 216 | Meter 10 Element 2 Power Factor | 0 | Meter 10 Element 2 Power Factor |
| AnalogInput | 217 | Meter 10 Element 2 Angle | 0 | Meter 10 Element 2 Angle |
| AnalogInput | 218 | Meter 10 Element 2 Current | 0 | Meter 10 Element 2 Current |
| AnalogInput | 219 | Meter 10 Element 2 Voltage | 0 | Meter 10 Element 2 Voltage |
| AnalogInput | 220 | Meter 11 Active Power | 0 | Meter 11 Active Power |
| AnalogInput | 221 | Meter 11 Reactive Power | 0 | Meter 11 Reactive Power |
| AnalogInput | 222 | Meter 11 Apparent Power | 0 | Meter 11 Apparent Power |
| AnalogInput | 223 | Meter 11 Power Factor | 0 | Meter 11 Power Factor |
| AnalogInput | 224 | Meter 11 Demand W | 0 | Meter 11 Demand W |



| | | | | |
|-------------|-----|-----------------------------------|---|-----------------------------------|
| AnalogInput | 225 | Meter 11 Demand W Present | 0 | Meter 11 Demand W Present |
| AnalogInput | 226 | Meter 11 Demand VA | 0 | Meter 11 Demand VA |
| AnalogInput | 227 | Meter 11 Demand VA Present | 0 | Meter 11 Demand VA Present |
| AnalogInput | 228 | Meter 11 Element 1 Power | 0 | Meter 11 Element 1 Power |
| AnalogInput | 229 | Meter 11 Element 1 Reactive Power | 0 | Meter 11 Element 1 Reactive Power |
| AnalogInput | 230 | Meter 11 Element 1 Apparent Power | 0 | Meter 11 Element 1 Apparent Power |
| AnalogInput | 231 | Meter 11 Element 1 Power Factor | 0 | Meter 11 Element 1 Power Factor |
| AnalogInput | 232 | Meter 11 Element 1 Angle | 0 | Meter 11 Element 1 Angle |
| AnalogInput | 233 | Meter 11 Element 1 Current | 0 | Meter 11 Element 1 Current |
| AnalogInput | 234 | Meter 11 Element 1 Voltage | 0 | Meter 11 Element 1 Voltage |
| AnalogInput | 235 | Meter 11 Element 2 Power | 0 | Meter 11 Element 2 Power |
| AnalogInput | 236 | Meter 11 Element 2 Reactive Power | 0 | Meter 11 Element 2 Reactive Power |
| AnalogInput | 237 | Meter 11 Element 2 Apparent Power | 0 | Meter 11 Element 2 Apparent Power |
| AnalogInput | 238 | Meter 11 Element 2 Power Factor | 0 | Meter 11 Element 2 Power Factor |
| AnalogInput | 239 | Meter 11 Element 2 Angle | 0 | Meter 11 Element 2 Angle |
| AnalogInput | 240 | Meter 11 Element 2 Current | 0 | Meter 11 Element 2 Current |
| AnalogInput | 241 | Meter 11 Element 2 Voltage | 0 | Meter 11 Element 2 Voltage |
| AnalogInput | 242 | Meter 12 Active Power | 0 | Meter 12 Active Power |
| AnalogInput | 243 | Meter 12 Reactive Power | 0 | Meter 12 Reactive Power |
| AnalogInput | 244 | Meter 12 Apparent Power | 0 | Meter 12 Apparent Power |
| AnalogInput | 245 | Meter 12 Power Factor | 0 | Meter 12 Power Factor |
| AnalogInput | 246 | Meter 12 Demand W | 0 | Meter 12 Demand W |
| AnalogInput | 247 | Meter 12 Demand W Present | 0 | Meter 12 Demand W Present |
| AnalogInput | 248 | Meter 12 Demand VA | 0 | Meter 12 Demand VA |
| AnalogInput | 249 | Meter 12 Demand VA Present | 0 | Meter 12 Demand VA Present |
| AnalogInput | 250 | Meter 12 Element 1 Power | 0 | Meter 12 Element 1 Power |
| AnalogInput | 251 | Meter 12 Element 1 Reactive Power | 0 | Meter 12 Element 1 Reactive Power |
| AnalogInput | 252 | Meter 12 Element 1 Apparent Power | 0 | Meter 12 Element 1 Apparent Power |
| AnalogInput | 253 | Meter 12 Element 1 Power Factor | 0 | Meter 12 Element 1 Power Factor |
| AnalogInput | 254 | Meter 12 Element 1 Angle | 0 | Meter 12 Element 1 Angle |
| AnalogInput | 255 | Meter 12 Element 1 Current | 0 | Meter 12 Element 1 Current |
| AnalogInput | 256 | Meter 12 Element 1 Voltage | 0 | Meter 12 Element 1 Voltage |
| AnalogInput | 257 | Meter 12 Element 2 Power | 0 | Meter 12 Element 2 Power |
| AnalogInput | 258 | Meter 12 Element 2 Reactive Power | 0 | Meter 12 Element 2 Reactive Power |
| AnalogInput | 259 | Meter 12 Element 2 Apparent Power | 0 | Meter 12 Element 2 Apparent Power |
| AnalogInput | 260 | Meter 12 Element 2 Power Factor | 0 | Meter 12 Element 2 Power Factor |
| AnalogInput | 261 | Meter 12 Element 2 Angle | 0 | Meter 12 Element 2 Angle |
| AnalogInput | 262 | Meter 12 Element 2 Current | 0 | Meter 12 Element 2 Current |
| AnalogInput | 263 | Meter 12 Element 2 Voltage | 0 | Meter 12 Element 2 Voltage |
| AnalogInput | 264 | Meter 13 Active Power | 0 | Meter 13 Active Power |
| AnalogInput | 265 | Meter 13 Reactive Power | 0 | Meter 13 Reactive Power |
| AnalogInput | 266 | Meter 13 Apparent Power | 0 | Meter 13 Apparent Power |
| AnalogInput | 267 | Meter 13 Power Factor | 0 | Meter 13 Power Factor |
| AnalogInput | 268 | Meter 13 Demand W | 0 | Meter 13 Demand W |
| AnalogInput | 269 | Meter 13 Demand W Present | 0 | Meter 13 Demand W Present |
| AnalogInput | 270 | Meter 13 Demand VA | 0 | Meter 13 Demand VA |
| AnalogInput | 271 | Meter 13 Demand VA Present | 0 | Meter 13 Demand VA Present |
| AnalogInput | 272 | Meter 13 Element 1 Power | 0 | Meter 13 Element 1 Power |
| AnalogInput | 273 | Meter 13 Element 1 Reactive Power | 0 | Meter 13 Element 1 Reactive Power |
| AnalogInput | 274 | Meter 13 Element 1 Apparent Power | 0 | Meter 13 Element 1 Apparent Power |
| AnalogInput | 275 | Meter 13 Element 1 Power Factor | 0 | Meter 13 Element 1 Power Factor |
| AnalogInput | 276 | Meter 13 Element 1 Angle | 0 | Meter 13 Element 1 Angle |
| AnalogInput | 277 | Meter 13 Element 1 Current | 0 | Meter 13 Element 1 Current |
| AnalogInput | 278 | Meter 13 Element 1 Voltage | 0 | Meter 13 Element 1 Voltage |
| AnalogInput | 279 | Meter 13 Element 2 Power | 0 | Meter 13 Element 2 Power |
| AnalogInput | 280 | Meter 13 Element 2 Reactive Power | 0 | Meter 13 Element 2 Reactive Power |
| AnalogInput | 281 | Meter 13 Element 2 Apparent Power | 0 | Meter 13 Element 2 Apparent Power |



| | | | | |
|-------------|-----|-----------------------------------|---|-----------------------------------|
| AnalogInput | 282 | Meter 13 Element 2 Power Factor | 0 | Meter 13 Element 2 Power Factor |
| AnalogInput | 283 | Meter 13 Element 2 Angle | 0 | Meter 13 Element 2 Angle |
| AnalogInput | 284 | Meter 13 Element 2 Current | 0 | Meter 13 Element 2 Current |
| AnalogInput | 285 | Meter 13 Element 2 Voltage | 0 | Meter 13 Element 2 Voltage |
| AnalogInput | 286 | Meter 13 Element 3 Power | 0 | Meter 13 Element 3 Power |
| AnalogInput | 287 | Meter 13 Element 3 Reactive Power | 0 | Meter 13 Element 3 Reactive Power |
| AnalogInput | 288 | Meter 13 Element 3 Apparent Power | 0 | Meter 13 Element 3 Apparent Power |
| AnalogInput | 289 | Meter 13 Element 3 Power Factor | 0 | Meter 13 Element 3 Power Factor |
| AnalogInput | 290 | Meter 13 Element 3 Angle | 0 | Meter 13 Element 3 Angle |
| AnalogInput | 291 | Meter 13 Element 3 Current | 0 | Meter 13 Element 3 Current |
| AnalogInput | 292 | Meter 13 Element 3 Voltage | 0 | Meter 13 Element 3 Voltage |
| AnalogInput | 293 | Meter 14 Active Power | 0 | Meter 14 Active Power |
| AnalogInput | 294 | Meter 14 Reactive Power | 0 | Meter 14 Reactive Power |
| AnalogInput | 295 | Meter 14 Apparent Power | 0 | Meter 14 Apparent Power |
| AnalogInput | 296 | Meter 14 Power Factor | 0 | Meter 14 Power Factor |
| AnalogInput | 297 | Meter 14 Demand W | 0 | Meter 14 Demand W |
| AnalogInput | 298 | Meter 14 Demand W Present | 0 | Meter 14 Demand W Present |
| AnalogInput | 299 | Meter 14 Demand VA | 0 | Meter 14 Demand VA |
| AnalogInput | 300 | Meter 14 Demand VA Present | 0 | Meter 14 Demand VA Present |
| AnalogInput | 301 | Meter 14 Element 1 Power | 0 | Meter 14 Element 1 Power |
| AnalogInput | 302 | Meter 14 Element 1 Reactive Power | 0 | Meter 14 Element 1 Reactive Power |
| AnalogInput | 303 | Meter 14 Element 1 Apparent Power | 0 | Meter 14 Element 1 Apparent Power |
| AnalogInput | 304 | Meter 14 Element 1 Power Factor | 0 | Meter 14 Element 1 Power Factor |
| AnalogInput | 305 | Meter 14 Element 1 Angle | 0 | Meter 14 Element 1 Angle |
| AnalogInput | 306 | Meter 14 Element 1 Current | 0 | Meter 14 Element 1 Current |
| AnalogInput | 307 | Meter 14 Element 1 Voltage | 0 | Meter 14 Element 1 Voltage |
| AnalogInput | 308 | Meter 14 Element 2 Power | 0 | Meter 14 Element 2 Power |
| AnalogInput | 309 | Meter 14 Element 2 Reactive Power | 0 | Meter 14 Element 2 Reactive Power |
| AnalogInput | 310 | Meter 14 Element 2 Apparent Power | 0 | Meter 14 Element 2 Apparent Power |
| AnalogInput | 311 | Meter 14 Element 2 Power Factor | 0 | Meter 14 Element 2 Power Factor |
| AnalogInput | 312 | Meter 14 Element 2 Angle | 0 | Meter 14 Element 2 Angle |
| AnalogInput | 313 | Meter 14 Element 2 Current | 0 | Meter 14 Element 2 Current |
| AnalogInput | 314 | Meter 14 Element 2 Voltage | 0 | Meter 14 Element 2 Voltage |
| AnalogInput | 315 | Meter 14 Element 3 Power | 0 | Meter 14 Element 3 Power |
| AnalogInput | 316 | Meter 14 Element 3 Reactive Power | 0 | Meter 14 Element 3 Reactive Power |
| AnalogInput | 317 | Meter 14 Element 3 Apparent Power | 0 | Meter 14 Element 3 Apparent Power |
| AnalogInput | 318 | Meter 14 Element 3 Power Factor | 0 | Meter 14 Element 3 Power Factor |
| AnalogInput | 319 | Meter 14 Element 3 Angle | 0 | Meter 14 Element 3 Angle |
| AnalogInput | 320 | Meter 14 Element 3 Current | 0 | Meter 14 Element 3 Current |
| AnalogInput | 321 | Meter 14 Element 3 Voltage | 0 | Meter 14 Element 3 Voltage |
| AnalogInput | 322 | Meter 15 Active Power | 0 | Meter 15 Active Power |
| AnalogInput | 323 | Meter 15 Reactive Power | 0 | Meter 15 Reactive Power |
| AnalogInput | 324 | Meter 15 Apparent Power | 0 | Meter 15 Apparent Power |
| AnalogInput | 325 | Meter 15 Power Factor | 0 | Meter 15 Power Factor |
| AnalogInput | 326 | Meter 15 Demand W | 0 | Meter 15 Demand W |
| AnalogInput | 327 | Meter 15 Demand W Present | 0 | Meter 15 Demand W Present |
| AnalogInput | 328 | Meter 15 Demand VA | 0 | Meter 15 Demand VA |
| AnalogInput | 329 | Meter 15 Demand VA Present | 0 | Meter 15 Demand VA Present |
| AnalogInput | 330 | Meter 15 Element 1 Power | 0 | Meter 15 Element 1 Power |
| AnalogInput | 331 | Meter 15 Element 1 Reactive Power | 0 | Meter 15 Element 1 Reactive Power |
| AnalogInput | 332 | Meter 15 Element 1 Apparent Power | 0 | Meter 15 Element 1 Apparent Power |
| AnalogInput | 333 | Meter 15 Element 1 Power Factor | 0 | Meter 15 Element 1 Power Factor |
| AnalogInput | 334 | Meter 15 Element 1 Angle | 0 | Meter 15 Element 1 Angle |
| AnalogInput | 335 | Meter 15 Element 1 Current | 0 | Meter 15 Element 1 Current |
| AnalogInput | 336 | Meter 15 Element 1 Voltage | 0 | Meter 15 Element 1 Voltage |
| AnalogInput | 337 | Meter 15 Element 2 Power | 0 | Meter 15 Element 2 Power |
| AnalogInput | 338 | Meter 15 Element 2 Reactive Power | 0 | Meter 15 Element 2 Reactive Power |



| | | | | |
|-------------|-----|--|---|--|
| AnalogInput | 339 | Meter 15 Element 2 Apparent Power | 0 | Meter 15 Element 2 Apparent Power |
| AnalogInput | 340 | Meter 15 Element 2 Power Factor | 0 | Meter 15 Element 2 Power Factor |
| AnalogInput | 341 | Meter 15 Element 2 Angle | 0 | Meter 15 Element 2 Angle |
| AnalogInput | 342 | Meter 15 Element 2 Current | 0 | Meter 15 Element 2 Current |
| AnalogInput | 343 | Meter 15 Element 2 Voltage | 0 | Meter 15 Element 2 Voltage |
| AnalogInput | 344 | Meter 15 Element 3 Power | 0 | Meter 15 Element 3 Power |
| AnalogInput | 345 | Meter 15 Element 3 Reactive Power | 0 | Meter 15 Element 3 Reactive Power |
| AnalogInput | 346 | Meter 15 Element 3 Apparent Power | 0 | Meter 15 Element 3 Apparent Power |
| AnalogInput | 347 | Meter 15 Element 3 Power Factor | 0 | Meter 15 Element 3 Power Factor |
| AnalogInput | 348 | Meter 15 Element 3 Angle | 0 | Meter 15 Element 3 Angle |
| AnalogInput | 349 | Meter 15 Element 3 Current | 0 | Meter 15 Element 3 Current |
| AnalogInput | 350 | Meter 15 Element 3 Voltage | 0 | Meter 15 Element 3 Voltage |
| AnalogInput | 351 | Meter 16 Active Power | 0 | Meter 16 Active Power |
| AnalogInput | 352 | Meter 16 Reactive Power | 0 | Meter 16 Reactive Power |
| AnalogInput | 353 | Meter 16 Apparent Power | 0 | Meter 16 Apparent Power |
| AnalogInput | 354 | Meter 16 Power Factor | 0 | Meter 16 Power Factor |
| AnalogInput | 355 | Meter 16 Demand W | 0 | Meter 16 Demand W |
| AnalogInput | 356 | Meter 16 Demand W Present | 0 | Meter 16 Demand W Present |
| AnalogInput | 357 | Meter 16 Demand VA | 0 | Meter 16 Demand VA |
| AnalogInput | 358 | Meter 16 Demand VA Present | 0 | Meter 16 Demand VA Present |
| AnalogInput | 359 | Meter 16 Element 1 Power | 0 | Meter 16 Element 1 Power |
| AnalogInput | 360 | Meter 16 Element 1 Reactive Power | 0 | Meter 16 Element 1 Reactive Power |
| AnalogInput | 361 | Meter 16 Element 1 Apparent Power | 0 | Meter 16 Element 1 Apparent Power |
| AnalogInput | 362 | Meter 16 Element 1 Power Factor | 0 | Meter 16 Element 1 Power Factor |
| AnalogInput | 363 | Meter 16 Element 1 Angle | 0 | Meter 16 Element 1 Angle |
| AnalogInput | 364 | Meter 16 Element 1 Current | 0 | Meter 16 Element 1 Current |
| AnalogInput | 365 | Meter 16 Element 1 Voltage | 0 | Meter 16 Element 1 Voltage |
| AnalogInput | 366 | Meter 16 Element 2 Power | 0 | Meter 16 Element 2 Power |
| AnalogInput | 367 | Meter 16 Element 2 Reactive Power | 0 | Meter 16 Element 2 Reactive Power |
| AnalogInput | 368 | Meter 16 Element 2 Apparent Power | 0 | Meter 16 Element 2 Apparent Power |
| AnalogInput | 369 | Meter 16 Element 2 Power Factor | 0 | Meter 16 Element 2 Power Factor |
| AnalogInput | 370 | Meter 16 Element 2 Angle | 0 | Meter 16 Element 2 Angle |
| AnalogInput | 371 | Meter 16 Element 2 Current | 0 | Meter 16 Element 2 Current |
| AnalogInput | 372 | Meter 16 Element 2 Voltage | 0 | Meter 16 Element 2 Voltage |
| AnalogInput | 373 | Meter 16 Element 3 Power | 0 | Meter 16 Element 3 Power |
| AnalogInput | 374 | Meter 16 Element 3 Reactive Power | 0 | Meter 16 Element 3 Reactive Power |
| AnalogInput | 375 | Meter 16 Element 3 Apparent Power | 0 | Meter 16 Element 3 Apparent Power |
| AnalogInput | 376 | Meter 16 Element 3 Power Factor | 0 | Meter 16 Element 3 Power Factor |
| AnalogInput | 377 | Meter 16 Element 3 Angle | 0 | Meter 16 Element 3 Angle |
| AnalogInput | 378 | Meter 16 Element 3 Current | 0 | Meter 16 Element 3 Current |
| AnalogInput | 379 | Meter 16 Element 3 Voltage | 0 | Meter 16 Element 3 Voltage |
| Accumulator | 0 | Meter 1 Active Energy Delivered Register | 0 | Meter 1 Active Energy Delivered Register |
| Accumulator | 1 | Meter 1 Active Energy Received Register | 0 | Meter 1 Active Energy Received Register |
| Accumulator | 2 | Meter 1 Reactive Energy Delivered Register | 0 | Meter 1 Reactive Energy Delivered Register |
| Accumulator | 3 | Meter 1 Reactive Energy Received Register | 0 | Meter 1 Reactive Energy Received Register |
| Accumulator | 4 | Meter 1 Apparent Energy Register | 0 | Meter 1 Apparent Energy Register |
| Accumulator | 5 | Meter 2 Active Energy Delivered Register | 0 | Meter 2 Active Energy Delivered Register |
| Accumulator | 6 | Meter 2 Active Energy Received Register | 0 | Meter 2 Active Energy Received Register |
| Accumulator | 7 | Meter 2 Reactive Energy Delivered Register | 0 | Meter 2 Reactive Energy Delivered Register |
| Accumulator | 8 | Meter 2 Reactive Energy Received Register | 0 | Meter 2 Reactive Energy Received Register |
| Accumulator | 9 | Meter 2 Apparent Energy Register | 0 | Meter 2 Apparent Energy Register |
| Accumulator | 10 | Meter 3 Active Energy Delivered Register | 0 | Meter 3 Active Energy Delivered Register |
| Accumulator | 11 | Meter 3 Active Energy Received Register | 0 | Meter 3 Active Energy Received Register |
| Accumulator | 12 | Meter 3 Reactive Energy Delivered Register | 0 | Meter 3 Reactive Energy Delivered Register |
| Accumulator | 13 | Meter 3 Reactive Energy Received Register | 0 | Meter 3 Reactive Energy Received Register |
| Accumulator | 14 | Meter 3 Apparent Energy Register | 0 | Meter 3 Apparent Energy Register |
| Accumulator | 15 | Meter 4 Active Energy Delivered Register | 0 | Meter 4 Active Energy Delivered Register |
| Accumulator | 16 | Meter 4 Active Energy Received Register | 0 | Meter 4 Active Energy Received Register |



| | | | | |
|-------------|----|---|---|---|
| Accumulator | 67 | Meter 14 Reactive Energy Delivered Register | 0 | Meter 14 Reactive Energy Delivered Register |
| Accumulator | 68 | Meter 14 Reactive Energy Received Register | 0 | Meter 14 Reactive Energy Received Register |
| Accumulator | 69 | Meter 14 Apparent Energy Register | 0 | Meter 14 Apparent Energy Register |
| Accumulator | 70 | Meter 15 Active Energy Delivered Register | 0 | Meter 15 Active Energy Delivered Register |
| Accumulator | 71 | Meter 15 Active Energy Received Register | 0 | Meter 15 Active Energy Received Register |
| Accumulator | 72 | Meter 15 Reactive Energy Delivered Register | 0 | Meter 15 Reactive Energy Delivered Register |
| Accumulator | 73 | Meter 15 Reactive Energy Received Register | 0 | Meter 15 Reactive Energy Received Register |
| Accumulator | 74 | Meter 15 Apparent Energy Register | 0 | Meter 15 Apparent Energy Register |
| Accumulator | 75 | Meter 16 Active Energy Delivered Register | 0 | Meter 16 Active Energy Delivered Register |
| Accumulator | 76 | Meter 16 Active Energy Received Register | 0 | Meter 16 Active Energy Received Register |
| Accumulator | 77 | Meter 16 Reactive Energy Delivered Register | 0 | Meter 16 Reactive Energy Delivered Register |
| Accumulator | 78 | Meter 16 Reactive Energy Received Register | 0 | Meter 16 Reactive Energy Received Register |
| Accumulator | 79 | Meter 16 Apparent Energy Register | 0 | Meter 16 Apparent Energy Register |
| Accumulator | 80 | Pulse Counter 1 register | 0 | Pulse Counter 1 register |
| Accumulator | 81 | Pulse Counter 2 register | 0 | Pulse Counter 2 register |
| Accumulator | 82 | Pulse Counter 3 register | 0 | Pulse Counter 3 register |
| Accumulator | 83 | Pulse Counter 4 register | 0 | Pulse Counter 4 register |
| Accumulator | 84 | Pulse Counter 5 register | 0 | Pulse Counter 5 register |
| Accumulator | 85 | Pulse Counter 6 register | 0 | Pulse Counter 6 register |
| Accumulator | 86 | Pulse Counter 7 register | 0 | Pulse Counter 7 register |
| Accumulator | 87 | Pulse Counter 8 register | 0 | Pulse Counter 8 register |
| Accumulator | 88 | Pulse Counter 9 register | 0 | Pulse Counter 9 register |
| Accumulator | 89 | Pulse Counter 10 register | 0 | Pulse Counter 10 register |
| Accumulator | 90 | Pulse Counter 11 register | 0 | Pulse Counter 11 register |
| Accumulator | 91 | Pulse Counter 12 register | 0 | Pulse Counter 12 register |

Example Single meter point:

This is a 500-074-02 with only one meter point configured.

| Object Type | Object Id | Object Name | Value | Description |
|-------------|-----------|----------------------------------|-------|----------------------------------|
| Device | 123456 | | | Triacta |
| AnalogInput | 0 | Meter 1 Active Power | 0 | Meter 1 Active Power |
| AnalogInput | 1 | Meter 1 Reactive Power | 0 | Meter 1 Reactive Power |
| AnalogInput | 2 | Meter 1 Apparent Power | 0 | Meter 1 Apparent Power |
| AnalogInput | 3 | Meter 1 Power Factor | 0 | Meter 1 Power Factor |
| AnalogInput | 4 | Meter 1 Demand W | 0 | Meter 1 Demand W |
| AnalogInput | 5 | Meter 1 Demand W Present | 0 | Meter 1 Demand W Present |
| AnalogInput | 6 | Meter 1 Demand VA | 0 | Meter 1 Demand VA |
| AnalogInput | 7 | Meter 1 Demand VA Present | 0 | Meter 1 Demand VA Present |
| AnalogInput | 8 | Meter 1 Element 1 Power | 0 | Meter 1 Element 1 Power |
| AnalogInput | 9 | Meter 1 Element 1 Reactive Power | 0 | Meter 1 Element 1 Reactive Power |
| AnalogInput | 10 | Meter 1 Element 1 Apparent Power | 0 | Meter 1 Element 1 Apparent Power |
| AnalogInput | 11 | Meter 1 Element 1 Power Factor | 0 | Meter 1 Element 1 Power Factor |
| AnalogInput | 12 | Meter 1 Element 1 Angle | 0 | Meter 1 Element 1 Angle |
| AnalogInput | 13 | Meter 1 Element 1 Current | 0 | Meter 1 Element 1 Current |
| AnalogInput | 14 | Meter 1 Element 1 Voltage | 0 | Meter 1 Element 1 Voltage |
| AnalogInput | 15 | Meter 1 Element 2 Power | 0 | Meter 1 Element 2 Power |
| AnalogInput | 16 | Meter 1 Element 2 Reactive Power | 0 | Meter 1 Element 2 Reactive Power |
| AnalogInput | 17 | Meter 1 Element 2 Apparent Power | 0 | Meter 1 Element 2 Apparent Power |
| AnalogInput | 18 | Meter 1 Element 2 Power Factor | 0 | Meter 1 Element 2 Power Factor |
| AnalogInput | 19 | Meter 1 Element 2 Angle | 0 | Meter 1 Element 2 Angle |



| | | | | |
|-------------|----|--|---|--|
| AnalogInput | 20 | Meter 1 Element 2 Current | 0 | Meter 1 Element 2 Current |
| AnalogInput | 21 | Meter 1 Element 2 Voltage | 0 | Meter 1 Element 2 Voltage |
| Accumulator | 0 | Meter 1 Active Energy Delivered Register | 0 | Meter 1 Active Energy Delivered Register |
| Accumulator | 1 | Meter 1 Active Energy Received Register | 0 | Meter 1 Active Energy Received Register |
| Accumulator | 2 | Meter 1 Reactive Energy Delivered Register | 0 | Meter 1 Reactive Energy Delivered Register |
| Accumulator | 3 | Meter 1 Reactive Energy Received Register | 0 | Meter 1 Reactive Energy Received Register |
| Accumulator | 4 | Meter 1 Apparent Energy Register | 0 | Meter 1 Apparent Energy Register |

Note: Some attention should be paid to configuration scenarios where the meter would be in combined mode. This is highlighted currently because of the element skip scenarios as associated with 2 Phase meters and is also why the full output of both the 500-074-02 and the 500-044-02 are presented here.

External Pulse input module 500-043-01

This module can be in all 4 slots so the maximum object appearance = 48 external pulse inputs and the associated data will be analog objects. This module can also be mixed with other module types. The values for the accumulators are floats. Intervals are not transmitted. In a mixed circuit these will be shared by 12 circuits with whatever is in the other slots.

The available data for this analog object is shown here.

| Property Name | Property Value |
|-------------------|---|
| object-identifier | (accumulator, 0) |
| object-name | Pulse Counter 1 register |
| object-type | accumulator |
| present-value | 5 |
| status-flags | {} |
| event-state | normal |
| out-of-service | FALSE |
| scale | float-scale: 1 |
| units | no-units |
| max-pres-value | 999999999999 |
| description | Pulse Counter 1 register |
| property-list | {present-value, status-flags, event-state, out-of-service, scale, units, max-pres-value, description} |



Measurement Module 500-044-01

Circuit counts for these are 16 3 Phase meters, 16 2 phase meters, 48 single phase meters. There are both Analog Inputs and analog accumulator values are available and shown in this data profile. All 4 slots in this case are populated with the same module type.

Analog Input Object

| Property Name | Property Value |
|---------------------------|------------------------|
| object-identifier | (analog-input, 1) |
| object-name | Meter 1 Reactive Power |
| object-type | analog-input |
| present-value | 0 |
| status-flags | {} |
| event-state | normal |
| out-of-service | FALSE |
| units | volt-amperes-reactive |
| description | Meter 1 Reactive Power |
| reliability | no-fault-detected |
| Proprietary property-1500 | unsigned: 0 |

Accumulator Object

| Property Name | Property Value |
|----------------------|---|
| object-identifier | (accumulator, 1) |
| object-name | Meter 1 Active Energy Received Register |
| object-type | accumulator |
| present-value | 277 |
| status-flags | {} |
| event-state | normal |
| out-of-service | FALSE |
| scale | float-scale: 1 |
| units | watt-hours |
| max-pres-value | 99999999999 |
| description | Meter 1 Active Energy Received Register |




PICS

Date: June 9, 2022
 Vendor Name: METERGY Solutions Inc., TRIACTA Division
 Product Name: GATEWAY/GATEWAY-S Series Multi Circuit Electricity Meter
 Product Model Number: *The following Configuration Guide strategizes product Model numbers, descriptions and how they appear. This excerpt from the GATEWAY Installation Guide Doc. 930-148-01-A00 Appendix 2 should be used to identify all of the possible models associated with this application for the GATEWAY/GATEWAY-S. This would also include meters without all of the modules installed or mixes of different modules. The rest of the model doesn't speak to configuration of the meter at all. It merely discusses as the document states, the voltage and the cabling ordering information. The meter is capable of being programmed in custom variants of the approved service configurations. Any combination of the 1 to 4 physical measurement module slots may be populated.*

The GATEWAY-S is the same strategy and uses the identical BACnet software but only has one module slot as opposed to 4.

Triacta GATEWAY™

Appendix 2: Triacta GATEWAY™ Part Number Configuration Guide





Appendix 2: Triacta GATEWAY-S Part Number Configuration Guide

G m - 6 x - y 0 6

| | | |
|--|---------------------|---|
| Measurement Module Type (5 Available, 12 inputs each) | 100mA CT Flex | 1 |
| | 333mV CT Flex | 3 |
| | Pulse Counter | 4 |
| | 80mA CT flex | 8 |
| | 80mA CT Residential | 9 |

| | |
|---------------------------|---|
| Operating Voltage 600 VAC | 6 |
|---------------------------|---|

| | | |
|--------------|-----------------------|-------|
| Jurisdiction | None | Blank |
| | Measurement Canada | M |

| | | |
|-------------------------------------|----------------|---|
| Wiring Module Type (2 Available) | None | 0 |
| | Screw Terminal | T |

If whip cable modules are required, select none (0), and order the GATEWAY whip cables modules separately

Application Software Version: v1.1.7-1005

Firmware Revision: N/A

BACnet Protocol Version: 1.0.0

BACnet Protocol Revision: 16.1

Product Description

The GATEWAY/GATEWAY-S Series electricity meters are designed for multi-tenant billing and cost allocation purposes. They are configurable to support 48/12 single element/single phase, 2 element/2-phase or 3 element/3-phase general service type configurations. They measure active, reactive and apparent energy, delivered and received. Multiple variants support different mixes of measurement modules in multiples of the service types expressed, using a selection of 80mA, 100mA secondary output transformers, 333mV secondary output transducers or pulse counters. The units and associated CTs are typically installed in an electrical room or a multi-tenant environment. The CTs are typically installed in an electrical panel.



BACnet Standardized Device Profile (Annex L)

| | |
|---|--|
| | BACnet Operator Workstation (B-OWS) |
| | BACnet Advanced Operator Workstation (B-AWS) |
| | BACnet Operator Display (B-OD) |
| | BACnet Building Controller (B-BC) |
| | BACnet Advanced Application Controller (B-AAC) |
| | BACnet Application Specific Controller (B-ASC) |
| X | BACnet Smart Actuator (B-SA) |
| | BACnet Smart Sensor (B-SS) |

BACnet Interoperability Building Blocks (BIBBs) Supported

| BIBB | Description of the BIBB | Supported (x: yes o: no) |
|---------------------|---|-----------------------------|
| DS | Data Sharing | |
| DS-RP-A | Data Sharing-ReadProperty-A | o |
| DS-RP-B | Data Sharing-ReadProperty-B | x |
| DS-RPM-A | Data Sharing-ReadPropertyMultiple-A | o |
| DS-RPM-B | Data Sharing-ReadPropertyMultiple-B | x |
| DS-WP-A | Data Sharing-WriteProperty-A | o |
| DS-WP-B | Data Sharing-WriteProperty-B | x |
| DS-WPM-A | Data Sharing-WritePropertyMultiple-A | o |
| DS-WPM-B | Data Sharing-WritePropertyMultiple-B | o |
| DS-COV-A | Data Sharing-Change Of Value-A | o |
| DS-COV-B | Data Sharing-Change Of Value-B | o |
| DS-COVP-A | Data Sharing-Change Of Value Property-A | o |
| DS-COVP-B | Data Sharing-Change Of Value Property-B | o |
| DS-COVU-A | Data Sharing-Change Of Value Unsubscribed-A | o |
| DS-COVU-B | Data Sharing-Change Of Value Unsubscribed-B | o |
| DS-V-A | Data Sharing-View-A | o |
| DS-AV-A | Data Sharing-Advanced View-A | o |
| DS-M-A | Data Sharing-Modify-A | o |
| DS-AM-A | Data Sharing-Advanced Modify-A | o |
| DS-WG-A | Data Sharing-WriteGroup-A | o |
| DS-WG-I-B | Data Sharing-WriteGroup-Internal-B | o |
| DS-WG-E-B | Data Sharing-WriteGroup-External-B | o |
| DS-VSI-B | Data Sharing-Value Source Information-B | o |
| DS-COVM-A | Data Sharing-Change Of Value Multiple-A | o |
| DS-COVM-B | Data Sharing-Change Of Value Multiple-B | o |
| Initiates ReadRange | Initiates ReadRange | o |
| Executes ReadRange | Executes ReadRange | o |
| DS-LSV-A | Data Sharing-Life Safety View-A | o |
| DS-LSAV-A | Data Sharing-Life Safety Advanced View-A | o |
| DS-LSM-A | Data Sharing-Life Safety Modify-A | o |
| DS-LSAM-A | Data Sharing-Life Safety Advanced Modify-A | o |
| DS-ACV-A | Data Sharing-Access Control View-A | o |
| DS-ACAV-A | Data Sharing-Access Control Advanced View-A | o |
| DS-ACM-A | Data Sharing-Access Control Modify-A | o |
| DS-ACAM-A | Data Sharing-Access Control Advanced Modify-A | o |



| | | |
|------------|--|---|
| DS-ACUC-A | Data Sharing-Access Control User Configuration-A | 0 |
| DS-ACUC-B | Data Sharing-Access Control User Configuration-B | 0 |
| DS-ACSC-A | Data Sharing-Access Control Site Configuration-A | 0 |
| DS-ACSC-B | Data Sharing-Access Control Site Configuration-B | 0 |
| DS-ACAD-A | Data Sharing-Access Control Access Door-A | 0 |
| DS-ACAD-B | Data Sharing-Access Control Access Door-B | 0 |
| DS-ACCDI-A | Data Sharing-Access Control Credential Data Input-A | 0 |
| DS-ACCDI-B | Data Sharing-Access Control Credential Data Input-B | 0 |
| DS-LO-A | Data Sharing-Lighting Output -A | 0 |
| DS-LOS-A | Data Sharing-Lighting Output Status-A | 0 |
| DS-ALO-A | Data Sharing-Advanced Lighting Output-A | 0 |
| DS-LO-B | Data Sharing-Lighting Output-B | 0 |
| DS-BLO-B | Data Sharing-Binary Lighting Output-B | 0 |
| DS-LOM-A | Data Sharing-Lighting Output Management-A | 0 |
| DS-LV-A | Data Sharing-Lighting View-A | 0 |
| DS-LAV-A | Data Sharing-Lighting Advanced View-A | 0 |
| DS-LM-A | Data Sharing-Lighting Modify-A | 0 |
| DS-LAM-A | Data Sharing-Lighting Advanced Modify-A | 0 |
| AE | Alarm and Event | |
| AE-N-A | Alarm and Event Management-Notification-A | 0 |
| AE-N-I-B | Alarm and Event Management-Notification Internal-B | 0 |
| AE-N-E-B | Alarm and Event Management-Notification External-B | 0 |
| AE-ACK-A | Alarm and Event Management-Acknowledge-A | 0 |
| AE-ACK-B | Alarm and Event Management-Acknowledge-B | 0 |
| AE-ASUM-A | Alarm and Event Management-Alarm Summary-A | 0 |
| AE-ASUM-B | Alarm and Event Management-Alarm Summary-B | 0 |
| AE-ESUM-A | Alarm and Event Management-Enrollment Summary-A | 0 |
| AE-ESUM-B | Alarm and Event Management-Enrollment Summary-B | 0 |
| AE-INFO-A | Alarm and Event Management-Information-A | 0 |
| AE-INFO-B | Alarm and Event Management-Information-B | 0 |
| AE-LS-A | Alarm and Event Management-LifeSafety-A | 0 |
| AE-LS-B | Alarm and Event Management-LifeSafety-B | 0 |
| AE-VN-A | Alarm and Event Management-View Notifications-A | 0 |
| AE-AVN-A | Alarm and Event Management-Advanced View Notifications-A | 0 |
| AE-VM-A | Alarm and Event Management-View and Modify-A | 0 |
| AE-AVM-A | Alarm and Event Management-Advanced View and Modify-A | 0 |
| AE-AS-A | Alarm and Event Management-Alarm Summary View-A | 0 |
| AE-ELV-A | Alarm and Event Management-Event Log View-A | 0 |
| AE-ELVM-A | Alarm and Event Management-Event Log View and Modify-A | 0 |
| AE-EL-I-B | Alarm and Event Management-Event Log-Internal-B | 0 |
| AE-EL-E-B | Alarm and Event Management-Event Log-External-B | 0 |
| AE-NF-B | Alarm and Event Management-Notification Forwarder-B | 0 |
| AE-NF-I-B | Alarm and Event Management-Notification Forwarder-Internal-B | 0 |
| AE-CRL-B | Alarm and Event Management-Configurable Recipient Lists-B | 0 |
| AE-TES-A | Alarm and Event Management-Temporary Event Subscription-A | 0 |
| AE-LSVN-A | Alarm and Event Management-Life Safety View Notifications-A | 0 |
| AE-LSAVN-A | Alarm and Event Management-Life Safety Advanced View Notifications-A | 0 |
| AE-LSVM-A | Alarm and Event Management-Life Safety View and Modify-A | 0 |
| AE-LSAVM-A | Alarm and Event Management-Life Safety Advanced View and Modify-A | 0 |



| | | |
|---------------|---|---|
| AE-AC-A | Alarm and Event Management-Access Control-A | 0 |
| AE-AC-B | Alarm and Event Management-Access Control-B | 0 |
| AE-ACAVN-A | Alarm and Event Management-Access Control Advanced View Notifications-A | 0 |
| AE-ACVM-A | Alarm and Event Management-Access Control View and Modify-A | 0 |
| AE-ACAVM-A | Alarm and Event Management-Access Control Advanced View and Modify-A | 0 |
| SCHED | Scheduling | |
| SCHED-A | Scheduling-A | 0 |
| SCHED-I-B | Scheduling-Internal-B | 0 |
| SCHED-E-B | Scheduling-External-B | 0 |
| SCHED-R-B | Scheduling-ReadOnly-B | 0 |
| SCHED-AVM-A | Scheduling-Advanced View and Modify-A | 0 |
| SCHED-VM-A | Scheduling-View and Modify-A | 0 |
| SCHED-WS-A | Scheduling-Weekly Schedule-A | 0 |
| SCHED-WS-I-B | Scheduling-Weekly Schedule Internal-B | 0 |
| SCHED-TMR-I-B | Scheduling-Timer-Internal-B | 0 |
| SCHED-TMR-E-B | Scheduling-Timer-External-B | 0 |
| T | Trending | |
| T-VMT-A | Trending-Viewing and Modifying Trends-A | 0 |
| T-VMT-I-B | Trending-Viewing and Modifying Trends Internal-B | 0 |
| T-VMT-E-B | Trending-Viewing and Modifying Trends External-B | 0 |
| T-ATR-A | Trending-Automated Trend Retrieval-A | 0 |
| T-ATR-B | Trending-Automated Trend Retrieval-B | 0 |
| T-VMMV-A | Trending-Viewing and Modifying Multiple Values-A | 0 |
| T-VMMV-I-B | Trending-Viewing and Modifying Multiple Values Internal-B | 0 |
| T-VMMV-E-B | Trending-Viewing and Modifying Multiple Values External-B | 0 |
| T-AMVR-A | Trending-Automated Multiple Value Retrieval-A | 0 |
| T-AMVR-B | Trending-Automated Multiple Value Retrieval-B | 0 |
| T-V-A | Trending-View-A | 0 |
| T-AVM-A | Trending-Advanced View and Modify-A | 0 |
| T-A-A | Trending-Archival-A | 0 |
| DM | Device Management | |
| DM-DDB-A | Device Management-Dynamic Device Binding-A | 0 |
| DM-DDB-B | Device Management-Dynamic Device Binding-B | x |
| DM-DOB-A | Device Management-Dynamic Object Binding-A | 0 |
| DM-DOB-B | Device Management-Dynamic Object Binding-B | x |
| DM-DCC-A | Device Management-DeviceCommunicationControl-A | 0 |
| DM-DCC-B | Device Management-DeviceCommunicationControl-B | 0 |
| DM-TM-A | Device Management-Text Message-A | 0 |
| DM-TM-B | Device Management-Text Message-B | 0 |
| DM-TS-A | Device Management-TimeSynchronization-A | 0 |
| DM-TS-B | Device Management-TimeSynchronization-B | x |
| DM-UTC-A | Device Management-UTCTimeSynchronization-A | 0 |
| DM-UTC-B | Device Management-UTCTimeSynchronization-B | x |
| DM-RD-A | Device Management-ReinitializeDevice-A | 0 |
| DM-RD-B | Device Management-ReinitializeDevice-B | 0 |
| DM-BR-A | Device Management-Backup and Restore-A | 0 |
| DM-BR-B | Device Management-Backup and Restore-B | 0 |
| DM-R-A | Device Management-Restart-A | 0 |
| DM-R-B | Device Management-Restart-B | 0 |
| DM-LM-A | Device Management-List Manipulation-A | 0 |



| | | |
|------------|--|---|
| DM-LM-B | Device Management-List Manipulation-B | 0 |
| DM-OCD-A | Device Management-Object Creation and Deletion-A | 0 |
| DM-OCD-B | Device Management-Object Creation and Deletion-B | 0 |
| DM-VT-A | Device Management-Virtual Terminal-A | 0 |
| DM-VT-B | Device Management-Virtual Terminal-B | 0 |
| DM-ANM-A | Device Management-Automatic Network Mapping-A | 0 |
| DM-ADM-A | Device Management-Automatic Device Mapping-A | 0 |
| DM-ATS-A | Device Management-Automatic Time Synchronization-A | 0 |
| DM-MTS-A | Device Management-Manual Time Synchronization-A | 0 |
| DM-SP-VM-A | Device Management-Slave Proxy-View and Modify-A | 0 |
| DM-SP-B | Device Management-Slave Proxy-B | 0 |
| DM-LOM-A | Device Management – Lighting Output Management-A | 0 |
| NM | Network Management | |
| NM-CE-A | Network Management-Connection Establishment-A | 0 |
| NM-CE-B | Network Management-Connection Establishment-B | 0 |
| NM-RC-A | Network Management-Router Configuration-A | 0 |
| NM-RC-B | Network Management-Router Configuration-B | 0 |
| NM-BBMDC-B | Network Management-BBMD Configuration-B | 0 |
| NM-BBMDC-A | Network Management-BBMD Configuration-A | 0 |
| NM-FDR-A | Network Management-Foreign Device Registration-A | 0 |
| NS | Network Security | |
| NS-SD | Network Security-Secure Device | 0 |
| NS-ED | Network Security-Encrypted Device | 0 |
| NS-MAD | Network Security-Multi-Application Device | 0 |
| NS-DMK-A | Network Security-Device Master Key-A | 0 |
| NS-DMK-B | Network Security-Device Master Key-B | 0 |
| NS-KS | Network Security-Key Server | 0 |
| NS-TKS | Network Security-Temporary Key Server | 0 |
| NS-SR | Network Security-Secure Router | 0 |
| NS-SP | Network Security-Security Proxy | 0 |
| GW | Gateway | |
| GW-VN-B | Gateway-Virtual Network-B | 0 |
| GW-EO-B | Gateway-Embedded Objects-B | 0 |
| AR | Audit Reporting | |
| AR-L-A | Audit Reporting-Logging- A | 0 |
| AR-R-B | Audit Reporting-Reporter-B | 0 |
| AR-R-S-B | Audit Reporting-Reporter-Simple-B | 0 |
| AR-F-B | Audit Reporting-Forwarder-B | 0 |
| AR-V-A | Audit Reporting-View-A | 0 |
| AR-AVM-A | Audit Reporting-Advanced View and Modify-A | 0 |



14. Device Profile

| Standard Profiles | Claimed | |
|--|---------|-------|
| | x: yes | o: no |
| Operator Interfaces | | |
| BACnet Cross-Domain Advanced Operator Workstation (B-XAWS) | 0 | |
| BACnet Advanced Operator Workstation (B-AWS) | 0 | |
| BACnet Operator Workstation (B-OWS) | 0 | |
| BACnet Operator Display (B-OD) | 0 | |
| Lighting Operator Interfaces | | |
| BACnet Advanced Lighting Workstation (B-ALWS) | 0 | |
| BACnet Lighting Operator Display (B-LOD) | 0 | |
| BACnet Advanced Lighting Control Station (B-ALCS) | 0 | |
| BACnet Lighting Control Station (B-LCS) | 0 | |
| BACnet Lighting Supervisor (B-LS) | 0 | |
| BACnet Lighting Device (B-LD) | 0 | |
| Life Safety Operator Interfaces | | |
| BACnet Advanced Life Safety Workstation (B-ALSW) | 0 | |
| BACnet Life Safety Workstation (B-LSWS) | 0 | |
| BACnet Life Safety Annunciator Panel (B-LSAP) | 0 | |
| Access Control Operator Interfaces | | |
| BACnet Advanced Access Control Workstation (B-AACWS) | 0 | |
| BACnet Access Control Workstation (B-ACWS) | 0 | |
| BACnet Access Control Security Display (B-ACSD) | 0 | |
| Controllers | | |
| BACnet Building Controller (B-BC) | 0 | |
| BACnet Advanced Application Controller (B-AAC) | 0 | |
| BACnet Application Specific Controller (B-ASC) | 0 | |
| BACnet Smart Actuator (B-SA) | x | |
| BACnet Smart Sensor (B-SS) | 0 | |
| Life Safety Controllers | | |
| BACnet Advanced Life Safety Controller (B-ALSC) | 0 | |
| BACnet Life Safety Controller (B-LSC) | 0 | |
| Access Control Controllers | | |
| BACnet Advanced Access Control Controller (B-AACC) | 0 | |
| BACnet Access Control Controller (B-ACC) | 0 | |
| Miscellaneous | | |
| BACnet Router (B-RTR) | 0 | |
| BACnet Gateway (B-GW) | 0 | |
| BACnet Broadcast Management Device (B-BBMD) | 0 | |
| BACnet Access Control Door Controller (B-ACDC) | 0 | |
| BACnet Access Control Credential Reader (B-ACCR) | 0 | |
| BACnet General (B-GENERAL) | 0 | |
| | | |



| Test Category | Supported (x: yes o: no) |
|--|-----------------------------|
| Basic Functionality Tests | X |
| Segmentation Support | O |
| BACnet/IP - Annex J - non-BBMD Functionality | X |
| BACnet/IP - Annex J - BBMD | X |
| Data Link Layer-ZigBee | O |
| Data Link Layer-Ethernet | O |
| Data Link Layer-ARCNET | O |
| Data Link Layer - MS/TP - Master Node | O |
| Data Link Layer - MS/TP - Slave Node | O |
| Routing | O |
| Object Tests | X |

Segmentation Capability

| |
|---|
| Able to transmit segmented messages: N/A Window Size: N/A |
| Able to receive segmented messages: N/A Window Size: N/A |

Standard Object Types Supported

Properties that are Writable and Optional are indicated.

| Accumulator | | |
|-------------------|---|---|
| Property | W | O |
| Description | | X |
| Event State | | |
| Max Pres Value | | |
| Object Identifier | | |
| Object Name | | |
| Object Type | | |
| Out Of Service | | |
| Present Value | | |
| Scale | | |
| Status Flags | | |
| Units | | |

| Analog Input | | |
|-------------------|---|---|
| Property | W | O |
| Description | | X |
| Event State | | |
| Object Identifier | | |
| Object Name | | |
| Object Type | | |
| Out Of Service | | |
| Present Value | | |
| Status Flags | | |
| Units | | |



| Device | | |
|---------------------------------|---|---|
| Property | W | O |
| APDU Timeout | X | |
| Application Software Version | | |
| Database Revision | | |
| Daylight Savings Status | X | |
| Description | X | X |
| Device Address Binding | | |
| Firmware Revision | | |
| Local Date | | X |
| Local Time | | X |
| Location | X | X |
| Max APDU Length Accepted | | |
| Model Name | | |
| Number Of APDU Retries | X | |
| Object Identifier | X | |
| Object List | | |
| Object Name | X | |
| Object Type | | |
| Profile Name | | X |
| Protocol Object Types Supported | | |
| Protocol Revision | | |
| Protocol Services Supported | | |
| Protocol Version | | |
| Segmentation Supported | | |
| System Status | | |
| UTC Offset | X | X |
| Vendor Identifier | | |
| Vendor Name | | |

Data Link Layer Options

| | |
|---|---|
| X | BACnet IP |
| X | BACnet IP, Foreign Device ISO 8802_3, Ethernet ANSI/ATA 878.1, 2.5 MB ARCNET ANSI/ATA 878.1, EIA_485 ARCNET, baud rate(s) _____ MS/TP master, baud rate(s) _____ MS/TP slave, baud rate(s) _____ Point-To-Point, EIA 232, baud rate(s) _____ Point-To-Point, modem, baud rate(s) _____ LonTalk, medium: _____ BACnet/Zigbee _____ Other _____ |



Character Sets Supported

| | | | |
|-------------------------------------|---------------------|--------------------------|-------------------|
| <input checked="" type="checkbox"/> | ISO 10646 (UTF-8) | <input type="checkbox"/> | ISO 8859-1 |
| <input type="checkbox"/> | ISO 10646 (UCS-2) | <input type="checkbox"/> | ISO 10646 (UCS-4) |
| <input type="checkbox"/> | IBM /Microsoft DBCS | <input type="checkbox"/> | JIS C 6626 |

Network Security Options

| | |
|-------------------------------------|------------------------------------|
| <input checked="" type="checkbox"/> | Non-secure Device |
| <input type="checkbox"/> | Secure Device |
| <input type="checkbox"/> | Multiple Application-Specific Keys |
| <input type="checkbox"/> | Supports encryption (NS-ED BIBB) |
| <input type="checkbox"/> | Key Server (NS-KS BIBB) |

